

**C.O.C.:** DW 111982

**REPORT No:** 23-008674 - Rev. 0

**Report To:**  
 City of Iqaluit  
 PO Box 460  
 Iqaluit, NU X0A 0H0

**CADUCEON Environmental Laboratories**  
 2378 Holly Lane  
 Ottawa, ON K1V 7P1

**Attention: Emmanuel Kayode**

DATE RECEIVED: 2023-Apr-27  
 DATE REPORTED: 2023-Apr-28  
 SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT:  
 P.O. NUMBER:

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
Coliforms - DC Media (Liquid)	9	OTTAWA	HALIPDA	2023-Apr-27	ECTC-001	MECP E3407

R.L. = Reporting Limit  
 NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an \*

Client I.D.	Sample I.D.	Date Collected	Parameter	Total Coliform (DC Media)	E coli (DC Media)	Background (DC Media)	Free Chlorine (Client Data)	Total Chlorine (Client Data)
			Units	CFU/100mL	CFU/100mL	CFU/100mL	mg/L	mg/L
			R.L.	1	1	1	-	-
				-	-	-	-	-
Reservoir #1	23-008674-1	2023-Apr-26		0	0	0	1.45	1.64
Reservoir #2	23-008674-2	2023-Apr-26		0	0	0	1.46	1.68
AV304	23-008674-3	2023-Apr-26		0	0	0	1.40	1.65
AV300B	23-008674-4	2023-Apr-26		0	0	0	1.39	1.57
AV358	23-008674-5	2023-Apr-26		0	0	0	1.00	1.25
AV134B	23-008674-6	2023-Apr-26		0	0	0	1.33	1.52
AV402	23-008674-7	2023-Apr-26		0	0	0	1.30	1.61
AVG29	23-008674-8	2023-Apr-26		0	0	0	1.00	1.25
ATB03	23-008674-9	2023-Apr-26		0	0	0	1.31	1.52

**Shelly Lozo**  
 Microbiology Supervisor